

Government of the Peoples Republic of Bangladesh Quality Control & Training Division, BRRL



DATA & REPORT SHEET

Memo No: LAB-25-06-22-03818-001-01 Date: 2025-06-22

Client Gazipur Road Dvision Lab Register No. 144 (B) 2024-2025.

1050365 PMP/e-Gp/23/GRD/2024-2025 Tender No. Contract No.

LAB-25-06-22-03818 Tracking Number Sample Sent By Client

Project/Work Name Periodic Maintenance Programe for DBS Wearing Course work from Ch. 12+550m to Ch. 16+053m. Ch.

16+286m to Ch. 18+000m and Ch. 21+140m to Ch. 25+450m of Kapasia-Pabur-Fuldi-Kaliganj Road under

Gazipur Road Division, during the year 2023-2024.

Sample Collection From: From Stackyard Sample Source Nill

Sample Sealing Status Sealed Sample Collected By EE (RHD)

Name of Test BITUMEN ROUTINE TEST

Item Name Others Test Code BRRL

Test Method **ASTM**

Associated Agency HREDI Construction Ltd.- MS Moni Enterprise- (JV), 827/1, 2nd Floor, Begum Rokeya Sarani Shewrapara,

Mirpur, Dhaka.

Date of sample receive :

Sample Description

16/06/2025 Date of Test : 19/06/2025

at Lab

Sample was supplied to the laboratory by Contractor's representative. Sample was carried in a pot. Amount of sample received is 5 kg approximately. Sample was sealed by Executive Engineer, RHD, Road Division,

Gazipur.

Test Performed By Akram Hossen Test Supervised By Sheikh Nafiur Nur Mousum

Assistant Research Officer

BITUMEN ROUTINE TEST

Name of the test	Unit	Result	Comments	Test Code	Spec 60/70	Spec 80/100
Penetration @25°C (100g, 5s)	0.1mm	70		ASTM D-5	60 - 70	80/100
Softening Point	°C	48		ASTM D-36	48 - 56	45 - 52
Ductility (@25°C)	CM	100		ASTM D-113	≥ 100cm	≥ 100cm
Loss on heating	%(of wt)	0.06		ASTM D-6	≤ 0.2	≤ 0.5
Penetrating drop after heating	%	82.86		ASTM D-5&6	≥ 80	≥ 80
Flash point	°C	300		ASTM D-92	≥ 250	≥ 250
Specific Gravity @25/25°C						
Descriptions	Unit	Specimen #1	Specimen #2			
Weight of Pycnometer (+Stopper), A	gm	30.380				
Weight of Pycnometer +Water, B	gm	56.135				
Weight Pycnometer partially filled with Bitumen, C	gm	44.827				
Pycnometer+Bitmen+Water, D	gm	56.307				
Density of Water at 25 °C, G25	Kg/m ³	1000				
Temperature of Water (T); °C,	°C	25				
Density of Water at Temperature T °C(GT)	Kg/m ³	1000				
SP. Gravity=((C-A)/{(B-A)-(D-C)})*(GT/G25)		1.0120				
Specific Gravity		1.0120				

Comment: Test was performed on the basis of supplied sample.

Test Performed By

22-Jun-2025

Akram Hossen Assistant Research Officer(AC) **Quality Control & Training** Division, BRRL

Test Approved By

22-Jun-2025 Sheikh Nafiur Nur Mousum Assistant Engineer **Quality Control & Training** Division, BRRL

Counter Signed By

22-Jun-2025

Jahangir Alam Sub Divisional Engineer Quality Control & Training Division, BRRL

Counter Signed By

22-Jun-2025

Dewan Md. Abdul Kader Executive Engineer(AC) **Quality Control & Training** Division, BRRL

This is a auto generated report by OLTMS system.