

Government of the Peoples Republic of Bangladesh Quality Control & Training Division, BRRL

DATA & REPORT SHEET

Memo No: LAB-25-06-24-03824-001-01 Date: 2025-06-24

Client : Munshiganj Road Dvision Lab Register No. : 153(B) 2024-2025.

Tender No. : 1111020 Contract No. : 60/e-GP/Mundiv/2024-2025

Tracking Number : LAB-25-06-24-03824 Sample Sent By : Client

Project/Work Name : Repair of Damaged & Undulated Pavement (Profile correction) by Aggregate Base Type-1, Premix

Bituminous Carpeting, Seal Coat work and Earth Work at 1st Km (P) & 2nd Km (P) of Hasara-Alampur-

Shibrampur-Kharshore Road (Z-8003) under Munshiganj Road Division

Sample Collection From: From Stackyard Sample Source: Ni

Sample Sealing Status : Sealed Sample Collected By : EE (RHD)

Name of Test : BITUMEN ROUTINE TEST

Item Name : Others Test Code : BRRL

Test Method : ASTM

Associated Agency : Mohammad Eunus & Brothers (Pvt) Ltd. Business Center, Equity G.F Forture Mail (7th Floor). 01 Baizid

Bostami Road, Nasirabad, Chattagram.

Date of sample receive:

Sample Description

23/06/2025

Date of Test

: 24/06/2025

at Lab

Sample was supplied to the laboratory by Contractor's representative. Sample was carried in a pot. Amount of sample received is 5 kg approximately. Sample was sealed by Executive Engineer, RHD, Road Division,

Munshigani.

Test Performed By : Akram Hossen

Test Supervised By

Sheikh Nafiur Nur Mousum

Assistant Research Officer

BITUMEN ROUTINE TEST

Name of the test	Unit	Result	Comments	Test Code	Spec 60/70	Spec 80/100
Penetration @25°C (100g, 5s)	0.1mm	61		ASTM D-5	60 - 70	80/100
Softening Point	°C	49		ASTM D-36	48 - 56	45 - 52
Ductility (@25°C)	CM	100		ASTM D-113	≥ 100cm	≥ 100cm
Loss on heating	%(of wt)	0.07		ASTM D-6	≤ 0.2	≤ 0.5
Penetrating drop after heating	%	91.80		ASTM D-5&6	≥ 80	≥ 80
Flash point	°C	320		ASTM D-92	≥ 250	≥ 250
Specific Gravity @25/25°C						
Descriptions	Unit	Specimen #1	Specimen #2			
Weight of Pycnometer (+Stopper), A	gm	30.3778				
Weight of Pycnometer +Water, B	gm	56.141				
Weight Pycnometer partially filled with Bitumen, C	gm	44.823				
Pycnometer+Bitmen+Water, D	gm	56.572				
Density of Water at 25 °C, G25	Kg/m ³	1000				
Temperature of Water (T); °C,	°C	25				
Density of Water at Temperature T °C(GT)	Kg/m ³	1000				
SP. Gravity=((C-A)/{(B-A)-(D-C)})*(GT/G25)		1.0308				
Specific Gravity		1.0308				

Comment: Test was performed on the basis of supplied sample.

Test Performed By

24-Jun-2025

Akram Hossen Assistant Research Officer(AC) Quality Control & Training Division, BRRL Test Approved By

24-Jun-2025 Sheikh Nafiur Nur Mousum Assistant Engineer Quality Control & Training Division, BRRL Counter Signed By

24-Jun-2025

Jahangir Alam Sub Divisional Engineer Quality Control & Training Division, BRRL Counter Signed By

24-Jun-2025

Dewan Md. Abdul Kader Executive Engineer(AC) Quality Control & Training Division, BRRL

This is a auto generated report by OLTMS system.